

Public Building Commission
June 1, 2017
CHS Storage Building Subcommittee Meeting
Cheshire High School, 525 South Main Street – Facilities Department Offices

Members Present: Jim McKenney, Committee Chairman
Members Absent: Steven Durkee
Richard Levy
Others Present: Vin Masciana, Cheshire Public Schools
Steve Trifone, Cheshire Public Schools
Victor Sandoval, Cheshire Public Schools
Richard Clavet, Cheshire Public Schools
George Noewatne, Public Works and Engineering

The design-build proposal was discussed and the following changes were recommended:

- Three spaces should be 28' wide and the 4th space should be 16' wide
- All doors will be 10' wide.
- Add alternate 480 s.f. including overhead
- Add 1 interior quad 110V outlet near the door of each bay.

Also required:

- An appropriately sized panel (est. 60 amp)
- Interior LED lighting with motion sensors
- Solar-powered attic vents (alternate)
- Photovoltaic activated exterior lights

The meeting adjourned at 8:30 AM.

Submitted by

George Noewatne, Director of Public Works and Engineering