

South Central Connecticut Regional Water Authority
90 Sargent Drive, New Haven, Connecticut 06511-5966 203.562.4020
<http://www.rwater.com>

September 25, 2020

Mr. William Voelker, Town Planner
Cheshire Town Hall
84 South Main Street
Cheshire CT 06410

Dear Mr. Voelker:

Re: 1721 Highland Avenue, parking lot expansion
Date of Site Plan: 9/10/20

The Regional Water Authority (RWA) has reviewed the above referenced application. A portion of the property is within the North Cheshire public water supply aquifer. The applicant is proposing additional parking. A portion of the additional parking area is located within the Aquifer Protection Area. Storm water will be managed through the use of a stormtech infiltration gallery. Based on the information submitted, we have the following comment:

1. As with catch basin #2, catch basin #1 should also be baffled. The catch basins should be inspected and cleaned out on a regular basis. The inspection and maintenance schedule should be included in the site plan.
2. During construction, all oil, paint, or other hazardous materials should be stored in a secondary container and removed to a locked indoor area with an impervious floor during non-work hours.

Thank you for the opportunity to comment on this application, if you have any questions please call me at 203 401-2741.

Sincerely,

REGIONAL WATER AUTHORITY



Ronald Walters
Senior Environmental Analyst