




**MEMORANDUM**  
**CHESHIRE FIRE DEPARTMENT**

250 MAPLE AVENUE, CHESHIRE, CONNECTICUT 06410  
Telephone (203) 272-1828 FAX (203) 272-7314

 EMAILED  
9/24/00 JR

**DATE:** 9/23/2020  
**TO:** Planning and Zoning Department  
**FROM:** Jack Casner, Chief of Department  
Michael Kozlowski, Deputy Fire Marshal  
**SUBJECT:** 1721 Highland Avenue Special Permit Modification

RECEIVED  
Town of Cheshire

Planning Dept.

---

The Fire Department has reviewed the above application for the planning and zoning process we recommend the following comments/stipulations.

If this application is approved code compliance plans must be submitted to the Building Official and Fire Marshal's Office prior to construction.

1. There is limited turning ability in this proposed parking area. The islands will need to be flat and mountable to allow emergency vehicle access. Final design of the islands will need to be obtained from the Fire Chief or his designee.