



RECEIVED  
Town of Cheshire  
NOV 13 2020

Planning Dept.

November 13, 2020

Mr. Don Nolte, Engineering Operations Manager  
Town of Cheshire  
84 South Main Street  
Cheshire, CT 06410

Re: Ball & Socket Arts, Inc.  
IWWC Application for expired CIWWC Permit #2014-020  
493 West Main Street, Cheshire, CT

Dear Mr. Nolte:

Anchor Engineering Services, Inc. reviewed the revised information prepared by Milone & MacBroom:

- Ball & Socket Arts – Phase I Plan sheets 5 & 11 of 11 dated May 19, 2014 and revised through 11/11/2020.
- Revised Stormwater Management Computations dated November 11, 2020.
- Comment Response Letter dated November 12, 2020.

The only comment that I would offer is that the underdrain and the impervious liner that were added to the underground detention be shown on and labeled on the Utility Plan.

If you have any questions please don't hesitate to contact me at (860) 633-8770.

Sincerely,

Denise P. Lord, P.E.  
Senior Civil Engineer