




MEMORANDUM

CHESHIRE FIRE DEPARTMENT

250 MAPLE AVENUE, CHESHIRE, CONNECTICUT 06410
Telephone (203) 272-1828 FAX (203) 272-7314

DATE: 11/17/2020

TO: Planning and Zoning Department

FROM: Jack Casner, Chief of Department 
Michael Kozlowski, Deputy Fire Marshal

SUBJECT: 61 Roslyn Drive Special Permit

The Fire Department has reviewed the above application for the planning and zoning process we recommend the following comments/stipulations. If this application is approved code compliance plans must be submitted to the Building Official and Fire Marshal's Office prior to construction.

1. A fire alarm system shall be installed so that occupants of both dwelling units are notified of a smoke or fire condition in the other.