



December 8, 2020

Mr. Don Nolte, Engineering Operations Manager
Town of Cheshire
84 South Main Street
Cheshire, CT 06410

Re: Subdivision & Storm Drainage Review
Orchard View Subdivision
Academy Road & Wiese Road, Cheshire, CT

Dear Mr. Nolte:

Anchor Engineering Services, Inc. received the following information prepared by Milone & MacBroom:

- Plan set sheets 1-17 dated October 14, 2020 and revised December 2,, 2020
- Drainage Report dated September 25, 2020 and revised December 1, 2020

Our previous comments have been addressed. The only outstanding concern (comment #1) is the suitability of the existing soils in the area of the relocated basin. The existing soil testing in this area indicate ledge and groundwater may be encountered at the proposed depth of the basin. It is recommended that the soils/groundwater be reviewed at the time of construction to verify that the basin will perform as designed.

If you have any questions regarding the above comments, please don't hesitate to contact me at (860) 633-8770.

Sincerely,

Denise P. Lord, P.E.
Senior Civil Engineer