

Public Building Commission
August 1, 2012 – 6:30 pm, Room 210, Town Hall
Pool Dehumidification Committee

Members Present: Mr. Ron Palumbo, Committee Chairman
Mr. Vin Robitaille, Committee Chairman
Mr. John Purtill, PBC Chairman
Mr. Dave Gavin, Committee Member (Energy Commission)
Mr. Mike O'Donnell, Committee Member

Others Present: Mr. Bob Ceccolini, Director Park & Rec
Ms. Sheila Adams, Pool Director
Mr. George Noewatne, Public Works Dept.
Mr. Denis Rioux, BL Companies
Mr. Greg Longo, BL Companies

The Chair called the meeting to order at 6:35 p.m. Roll was called and it was determined a quorum was present.

Denis Rioux discussed the packet dated July 31, 2012 and ventilation options matrix.

Greg Longo, BL Companies, stated the following:

- Above 65% with relative humidity of 70%, will present a problem with the design
- Option #2 saves about \$14,000 in utility costs vs. option #1, so the payback is about 6 months
- No penetrations to bubble, air exchange takes place with underground duct and distribution via duct sock

Motion made by Mr. Robitaille, and seconded by Ron Palumbo. The committee endorses and presents Option #2 to full PBC for approval, subject to modification approval by State Building Official. If the modification is not approved, the committee endorses Option #4. Motion carried unanimously.

Motion by Mr. Palumbo to adjourn meeting at 7:05pm. Motion seconded by Mr. Gavin and carried unanimously. Meeting adjourned at 7:05pm

Submitted by:

George Noewatne